

DEPARTMENT OF TRANSPORTATION

ESC/OE MS #43
1727 30TH Street, 2ND Floor
Sacramento, CA 95816



August 10, 2000

01-Lak-29-56.1/57.3
01-380204
ACNH-P029(086)E

Addendum No. 2

Dear Contractor:

This addendum is being issued to the contract for construction on State highway in LAKE COUNTY NEAR KELSEYVILLE AT KELSEY CREEK BRIDGE.

Submit bids for this work with the understanding and full consideration of this addendum. The revisions declared in this addendum are an essential part of the contract.

Bids for this work will be opened on August 15, 2000.

This addendum is being issued to revise the project plans.

Project Plan Sheet 8 is revised as follows: Under "Steel Sheet Pile Notes," "Minimum Thickness = 10 mm" is changed to "Minimum Thickness = 9.5 mm."

Project Plan Sheet 11 is revised as follows: On the "Welded Alternative" for the "Shear Stud Detail (Abutment)," "19mm diameter High Strength bolt" is changed to "19mm diameter ASTM: A108 stud."

Project Plan Sheet 11 is revised as follows: On the "Welded Alternative" for the "Shear Stud Detail (Piers)," "19mm diameter High Strength bolt" is changed to "19mm diameter ASTM: A108 stud."

To Proposal and Contract book holders:

Indicate receipt of this addendum by filling in the number of this addendum in the space provided on the signature page of the proposal.

Submit bids in the Proposal and Contract book you now possess. Holders who have already mailed their book will be contacted to arrange for the return of their book.

Inform subcontractors and suppliers as necessary.

This office is sending this addendum by confirmed facsimile to all book holders to ensure that each receives it.

If you are not a Proposal and Contract book holder, but request a book to bid on this project, you must comply with the requirements of this letter before submitting your bid.

Sincerely,

ORIGINAL SIGNED BY

NICK YAMBAO, Chief
Office of Plans, Specifications & Estimates
Division of Office Engineer